

Catalogue of Accessible Issues- Walkerton Community Centre

Year Identified	Area	Accessibility Concern	Projected Fix	Notes	Status	Cost
Exterior Building						
2024	Elevator Lift	Lower signage on lift door.	January 2025	Elevation of signs are difficult for individuals in scooters, wheelchairs, walkers etc. to see clearly	DONE	
2024	Side Main Entrance	Signage that clearly defines entrance will take you to 1st floor, use lift for 2nd floor	January 2025		Ordered- to be installed	
2024	Side Main Entrance	Automatic door push button should increase time between opening and closing	January 2025		DONE	
Interior First Floor						
2024	Main Lobby Area	Relocate Garbage, recycling bins from below counters	9/11/2024		DONE	
2024	Main Lobby Area	Concession menu screen improve Colour contrast	9/12/2024	Black on white is a better visual contrast than white on black	DONE	
2024	Main Lobby Area	Lower AED		Remove garbage cans located under	DONE	
2024	Main Lobby Area	New ramp and viewing platform change railings to be return to post railings	Estimate by January 2025-Thomas	Handrails should continue and curve to floor or wall as a guide for the user's hand to know something is changing.	DONE- Feb.25, 2025	
2024	Main Lobby Area	New ramp and viewing platform railing over hang too long at entrance to ramp, cut			DONE	
2024	Main Lobby Area	Customer Service Desk/ Reception: Install speaker amplification device				Estimate from Balaklava-\$1600
2024	Main Lobby Area	Customer Service Desk/ Reception: Remove Brochures from this area in sight line	9/11/2024	The counter is cluttered and needs to be clear	DONE	
2024	Designated Accessible Washroom	remove stall walls, create open space	Jan-25		DONE	
2024	Designated Accessible Washroom	Remove lost and found	Jan-25		DONE	
2024	Designated Accessible Washroom	Raise sink curtain or remove	Feb.27, 2025		In current progress	
2024	Designated Accessible Washroom	Toilet is too low, needs to be higher	Jan-25		DONE	
2024	Designated Accessible Washroom	Replace support bars with T-Bars not horizontal bars	Feb-25		DONE	
2024	Designated Accessible Washroom	Toilet paper dispenser should be spaced from T-bar	Feb-25		DONE	
2024	Ice Arena	Remove side ramp completely	Dec.10, 2024		DONE	