

Report to Council

Report Title:	July 2020 Water and Wastewater Maintenance Report		
Prepared By:	Gregg Furtney, Director of Operations		
Department:	Utilities		
Date:	August 11, 2020		
Report Number:	UT2020-10	File Number:	C11UT
Attachments:	July 2020 Report		

Recommendation:

That the Council of the Municipality of Brockton hereby receives Report Number UT2020-10 – July 2020 Water and Wastewater Maintenance Report, prepared by Gregg Furtney, Director of Operations for information purposes.

Report:

Background:

The following report summarizes operational data, maintenance activities, and compliance issues identified during the Operating Month of July 2020.

Analysis:

Chepstow Drinking Water System: Regulatory Issue

July 19, 2020 - Due to a UV issue (possibly caused by a power outage), an adverse water quality incident occurred. The UV system was restored and the operator verified that adequate secondary disinfection was maintained during the UV issues. The incident was reported to the MOECC and Health Unit. The UV lockouts were also verified at a later date by ICS Instrumentation.

There were no other compliance or regulatory issues with regards to the operations or maintenance of the other two water treatment facilities or the wastewater treatment plant.

Sustainability Checklist:

What aspect of the Brockton Sustainable Strategic Plan does the content/recommendations in this report help advance?

- Do the recommendations help move the Municipality closer to its Vision? Yes
- Do the recommendations contribute to achieving Cultural Vibrancy? Yes


- Do the recommendations contribute to achieving Economic Prosperity? N/A
- Do the recommendations contribute to Environmental Integrity? Yes
- Do the recommendations contribute to the Social Equity? N/A

Financial Impacts/Source of Funding:

- Do the recommendations represent a sound financial investment from a sustainability perspective? Yes

There are no financial impacts associated with this report.

Reviewed By:



Trish Serratore, Chief Financial Officer

Respectfully Submitted by:



Gregg Furtney, Director of Operations

Reviewed By:



Sonya Watson, Chief Administrative Officer