

B. M. ROSS AND ASSOCIATES LIMITED
Engineers and Planners
62 North Street, Goderich, ON N7A 2T4
p. (519) 524-2641 www.bmross.net

File No. 19014

VIA EMAIL ONLY

January 12, 2021

Gregg Furtney, Director of Operations
Municipality of Brockton
100 Scott Street, P.O. Box 68,
Walkerton, ON N0G 2V0

**RE: Municipality of Brockton
Quotation – Pre-Selected Diesel Generator Set;
Walker West Booster Pumping Station**

Quotations have been received and reviewed for the outdoor standby diesel generator set being preselected for the Walker West Booster Pumping Station. Copies of the quotations were previously sent to you electronically for your records. A summary of the three quotations received, and our comments follow.

Supplier	Price (Incl. HST)	Delivery (weeks after P.O.)	Engine	Generator
Sommers Generator Systems	\$60,901.35	14-16 weeks (after P.O.)	Perkins 1104D- E44TAG2	Stamford, UCI274D
Toromont Cat Power Systems	\$66,590.90	-	Caterpillar D80	-
Cummins Canada ULC	\$68,398.90	13 weeks (after drawing approvals)	Cummins QSB5- G13	Cummins C80D6C

The Sommers submission has been reviewed and exceptions from the specifications have been discussed with Sommers and explanations have been provided, with some exceptions being removed from their original bid submission.

The Cummins submission meets the requirements of the specifications. The Toromont submission did not meet all requirements of the specifications and has quoted an additional \$2,100 to comply with the specifications.

Cummins and Toromont each submitted bids for an 80-kW outdoor standby generator, per the specification and Sommers submitted a bid for a 100-kW outdoor standby generator, as they do not currently supply 80-kW generators.

Other general observations regarding the generator submissions include:

- All generator sets are supplied complete with sub base fuel tank, acoustic enclosure and set controller.
- The bid pricing is in line with the most recent budget amount.
- Sommers includes a 2 yr./3,000 hour limited warranty.

We have dealt with Sommers on several projects, and we note they have many Ontario installations. We believe that the 100-kW generator proposed by Sommers will provide satisfactory performance for this application and we therefore recommend acceptance of the Sommers bid for incorporation into this project.

Please let me know at your earliest convenience if you are in agreement with the recommendation, and we will send a letter to Sommers confirming of what is required by the Municipality to initiate the purchasing process.

If you have any questions or comments regarding our review of this quotation, please do not hesitate to contact us.

Yours very truly

B. M. ROSS AND ASSOCIATES LIMITED

Per 
Brock V.C. Spencer, P. Eng.

BVCS:es

c.c. Dave Runge, Runge & Associates Inc.